


kitty@caledonian-cables.com or kitty@caledonian-cables.co.uk

# PAS 5308 Cable Part 2 Type 2 PVC-IS-OS-SWA-PVC

### **Application**


These cables are designed to connect electrical instrumentation and communication systems in and around process plants and similar applications, Generally used to transmit analogue or digital signals in measurement and process control where chemicals may be present. The armoured version are well adapted to underground use in industrial applications where chemical and mechanical protections are needed (refinery areas, chemical plant...). The individual screening of each pair limits the consequence of crosstalk.

#### Construction



Conductor	Annealed copper, sizes: 0.5mm² and 0.75mm² mulitistranded(Class 5), 1.5mm²					
	and 2.5mm² multistranded(Class 2) to BS EN 60228					
Insulation	PVC to BS EN 50290-2-21:2002, grade TI51					
Pairing	Two insulated conductors uniformly twisted together with a lay not exceeding					
	100mm, Two-pair cables without individual pair screens (quads) shall have four					
	cores laid in quad formation round a central dummy					
Colour code	See technical information					
Individual screen	Aluminium/polyester tape is applied over each pair metallic side down in contact					
	with tinned copper drain wire, 0.5mm²					
Binder tape	Non-hygroscopic binder tape of minimum thickness 0.023 mm					








Collective screen	Aluminium/polyester tape is applied over the laid up pairs metallic side down in contact with tinned copper drain wire, 0.5mm²				
Inner Sheath	Extruded sheath of a PVC compound conforming to BS EN 50290-2-22:2002, grade TM51				
Amour	Galvanized steel wire armour				
Outer sheath	Extruded sheath of a PVC compound conforming to BS EN 50290-2-22:2002, grade TM51				
Sheath colour	Generally black				

## **Electrical Properties**

**Temperature range:** above 0°C( fixed installation)

-15°C to +65°C(during operation)

Conductor Area Size		mm²	0.5	0.5	1	1.5	2.5	
Conductor Stranding		No. x mm	1 x 0.8	16 x 0.2	1 x 1.13	7 x 0.53	7 x 0.67	
Conductor resistance max		ohm/km	36.8	39.7	18.4	12.3	7.6	
Insulation resistance min	Individual conductor	Gohm/km	5	5	5	5	5	
	individual screen	Mohm/km	1	1	1	1	1	
Capacitance u kHz(pair to pai		pF/250m	250					
Max. Mutual Capacitance @ 1 kHz for Non OS or OS cables (except one-pair and two-pairs)		pF/m	75	75	75	85	105	
Max. Mutual Capacitance @ 1 kHz IS/OS cables (include 1 pair and 2 pair)		pF/m	115	115	115	120	140	
Max. L/R Ratio for adjacent cores(Inductance/ Resistance)		μH/ohm	25	25	25	40	60	
Test voltage		V	2000	2000	2000	2000	2000	
Rated voltage		V	300/500	300/500	300/500	300/500	300/500	





### **Parameter**

Number of Pairs	Nominal Thickness of Insulation	Nominal Thickness of bedding	Nominal Diameter over Bedding	Nominal Thickness of Armour	Nominal Diameter over Armour	Nominal Thickness of Sheath	Nominal Diameter of Cable		
	mm	mm	mm	mm	mm	mm	mm		
		stranded	conductor	0.5 mm² (16/	0.20mm)				
2	0.6	0.9	9.7	0.9	11.5	1.4	14.3		
5	0.6	1	12.8	1.25	15.1	1.5	18.1		
10	0.6	1.2	18	1.6	21.2	1.7	24.6		
15	0.6	1.3	20.9	1.6	24.1	1.8	27.7		
20	0.6	1.4	23.6	1.6	26.8	1.9	30.6		
30	0.6	1.6	28.2	1.6	31.4	2	35.4		
50	0.6	1.8	36.1	2	40.1	2.2	44.5		
	stranded conductor 0.75 mm² (24/0.20mm)								
2	0.6	0.9	10.4	0.9	12.2	1.4	15		
5	0.6	1	13.5	1.25	16	1.5	19		
10	0.6	1.2	19.4	1.6	22.6	1.7	26		
15	0.6	1.4	22.8	1.6	26	1.8	29.6		
20	0.6	1.5	25.8	1.6	29	1.9	32.8		
30	0.6	1.6	30.5	2	34.5	2.1	38.7		
50	0.6	1.9	39.3	2.5	44.3	2.3	48.9		
		strande	d conductor	1.5 mm² (7/0	).53mm)				
2	0.6	1	12.1	1.25	14.6	1.5	17.6		
5	0.6	1.1	15.8	1.25	18.3	1.6	21.5		
10	0.6	1.4	22.9	1.6	26.1	1.8	29.7		
15	0.6	1.5	26.6	1.6	29.8	1.9	33.6		
20	0.6	1.6	30.1	2	34.1	2.1	38.3		
30	0.6	1.8	35.8	2	39.8	2.2	44.2		
50	0.6	2.2	46.2	2.5	51.2	2.5	56.2		
	stranded conductor 2.5 mm² (7/0.67mm)								
2	0.6	1	13.5	1.25	16	1.5	19		
5	0.6	1.2	17.9	1.6	21.1	1.7	24.5		
10	0.6	1.5	25.9	1.6	29.1	1.9	32.9		
15	0.6	1.6	30.1	2	34.1	2.1	38.3		





# Any inquiries, please feel free to contact kitty@caledonian-cables.com or kitty@caledonian-cables.co.uk

Number of Pairs	Nominal Thickness of Insulation	Nominal Thickness of bedding	Nominal Diameter over Bedding	Nominal Thickness of Armour	Nominal Diameter over Armour	Nominal Thickness of Sheath	Nominal Diameter of Cable
	mm	mm	mm	mm	mm	mm	mm
20	0.6	1.8	34.3	2	38.3	2.2	42.7
30	0.6	2	40.8	2.5	45.8	2.4	50.6
50	0.6	2.4	52.6	2.5	57.6	2.7	63